

## ANALOG INSULATION TESTER **PDM1529S**

## **APPLICATIONS AND FEATURES**

This instrument is a DC insulation resistance tester to measure the insulation resistance of electric lines and electric equipment.

- Test voltage DC1000V/500V/250V
- Easy viewing and readable scale graduations
- •One-shot or continuous measurement push switch
- DCV measurement range(DC60V)
- Auto discharge function
- Inner battery check range

## **SPECIFICATIONS**

Standard accessories included

	Measuring range		Best accuracy
MΩ	1000V/2000MΩ		1st effective measurement range : ±5% of full scale
(InsulationResistance)	500V/ 100MΩ 250V/ 100MΩ		2nd effective measurement range : ±10% of full scale
DCV	60V		±5% of full scale
ACV	600V		±5% of full scale
Rated measuring current	1~1.2mA		
Meter type		Internal magnet, Taut-band meter(48µA)	
AC rectifier form		Half-wave rectification(Mean value indication rms value converted)	
Accuracy assurance temperature /		23±5°C	
humidity		75%RH or below No condensation	
Operating temperature / humidity		0°C~43°C	
		80%RH or below No condensation	
Storage temperature / humidity		-10°C~50°C	
		70%RH or below No condensation	
Operating environment		Altitude 2000m or less, environmental pollution degree II	
Power consumption		Approx. 2.6W(At 1000V/2000MΩ range)	
Battery consumption		Checked by BATTERY CHECK range	
Safety standards		IEC61010-1 CAT.III 600V	
IP rate		IP20	
Battery		6LR61(9V) x 1	
Size / Mass		H144 x W99 x D43mm / 310g	

Test lead(TL-508Sa), Carrying case(C-08S), Instruction manual

A battery for monitoring has been installed prior to shipment from the factory. It may be discharged before the expiration of the described battery life. This battery is used to check the functions and performance of the product. Specifications and external appearance of the product described above may be revised for modification without prior notice.

Cosinus Messtechnik GmbH \* Rotwandweg 4 \* D-82024 Taufkirchen Tel.: 089-665594-0 \* Fax: 089-665594-30 \* Web: www.cosinus.de \* eMail: office@cosinus.de

